
D90/LEDN10DX1T1



recessed luminaire • round

Application : General office area’s, Auditoria, General education area’s, Patient rooms, General healthcare area’s

housing: polycarbonate

light source : LED • 4000 K

optics : reflector and lens • polycarbonate (PC) with aluminium thin film, satin look • wide-angle

UGR classification : <=16

luminous flux: 1150 lm

luminous efficacy : 112 lm/W

LLMF: 99% @ 50khrs (Tq=25°C)

Product information

Mechanical properties

dimensions : 190 mm x 107 mm

cut-out size : 175 mm x 107 mm

colour: RAL9003-signalwhite

trim: flat trim

type : individual luminaire

IP: IP20, IP54 from below

IK: IK06

Electrical properties

driver: DALI dimmable

power : 10.3 W

voltage : 220-240V

frequency : 50-60Hz AC/DC

photobiological safety : EN 62471: RISK GROUP 1 UNLIMITED

ETAP tomorrow's light

This document has been compiled by ETAP with the greatest possible care. However, the information contained in this publication is not binding and may change due to technical development. ETAP is not liable for any damage whatsoever resulting from the use of this document.
www.etaplighting.com // Made in Belgium

Luminance


luminous flux : 1150 lm

luminous efficacy : 112 lm/W

luminance @ 65° = : 1000 cd/m²

UGR classification =: <=16

luminous area : 0.02 m²



Average Luminances (Cd/m²) for 1150lm

Gamma	C0	C30	C45	C60	C90
45°	11581	11581	11581	11581	11581
50°	5718	5718	5718	5718	5718
55°	1022	1022	1022	1022	1022
60°	107	107	107	107	107
65°	21	21	21	21	21
70°	2	2	2	2	2
75°	0	0	0	0	0
80°	0	0	0	0	0
85°	0	0	0	0	0

Classifications

CIE: 900 / 1000 / 1000 / 1000 / 1000

CIE FLUXCODE : 0.90 / 1.00 / 1.00 / 1.00 / 1.00

BZ: BZ1

CAE: Symmetrical

DIN: A60 (Nach Arbeitsblatt 7)

DIN_U: Phi u = 1.00

DIN_SU: Phi su = 0.81

UTE: 1.00 A + 0.00 T

ETAP tomorrow's light

This document has been compiled by ETAP with the greatest possible care. However, the information contained in this publication is not binding and may change due to technical development. ETAP is not liable for any damage whatsoever resulting from the use of this document.
www.etaplighting.com // Made in Belgium

Lifetime Data (Tq=25.0°C)

Time(khrs)	LLMF(%)	Cx(%)
10	100	2
20	100	4
30	100	6
40	99	8
50	99	10
60	99	12

Luminous intensities in cd

Intensity for 1150lm

Gamma	C0	C45	C90
0°	929.4	929.4	929.4
5°	912.7	912.7	912.7
10°	879.2	879.2	879.2
15°	873.5	873.5	873.5
20°	861.2	861.2	861.2
25°	799.9	799.9	799.9
30°	689.2	689.2	689.2
35°	508.8	508.8	508.8
40°	291.7	291.7	291.7
45°	156.5	156.5	156.5
50°	70.2	70.2	70.2
55°	11.2	11.2	11.2
60°	1.0	1.0	1.0
65°	0.2	0.2	0.2
70°	0.0	0.0	0.0
75°	0.0	0.0	0.0
80°	0.0	0.0	0.0
85°	0.0	0.0	0.0
90°	0.0	0.0	0.0

UGR classification =

Corrected Glare Ratings for a Total Lamp Flux of 1150lm (S = 0.25H)

	Room Reflection Factors (%)									
Ceiling	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor	20	20	20	20	20	20	20	20	20	20
Room Dimensions	**Viewed Crosswise**					**Viewed Endwise**				
X = 2H Y = 2H	16.9	18.3	17.2	18.6	18.8	16.9	18.3	17.2	18.6	18.8
Y = 3H	16.8	18.0	17.1	18.3	18.5	16.8	18.0	17.1	18.3	18.5
Y = 4H	16.7	17.8	17.0	18.1	18.4	16.7	17.8	17.0	18.1	18.4
Y = 6H	16.6	17.6	17.0	17.9	18.3	16.6	17.6	17.0	17.9	18.3
Y = 8H	16.6	17.6	16.9	17.9	18.2	16.6	17.6	16.9	17.9	18.2
Y = 12H	16.5	17.5	16.9	17.8	18.1	16.5	17.5	16.9	17.8	18.1
X = 4H Y = 2H	16.7	17.8	17.0	18.1	18.4	16.7	17.8	17.0	18.1	18.4
Y = 3H	16.5	17.5	16.9	17.8	18.1	16.5	17.5	16.9	17.8	18.1
Y = 4H	16.5	17.3	16.9	17.6	18.0	16.5	17.3	16.9	17.6	18.0
Y = 6H	16.4	17.1	16.8	17.5	17.9	16.4	17.1	16.8	17.5	17.9
Y = 8H	16.4	17.0	16.8	17.4	17.8	16.4	17.0	16.8	17.4	17.8
Y = 12H	16.3	16.9	16.8	17.3	17.8	16.3	16.9	16.8	17.3	17.8
X = 8H Y = 4H	16.4	17.0	16.8	17.4	17.8	16.4	17.0	16.8	17.4	17.8
Y = 6H	16.3	16.8	16.7	17.3	17.7	16.3	16.8	16.7	17.3	17.7
Y = 8H	16.2	16.7	16.7	17.2	17.7	16.2	16.7	16.7	17.2	17.7
Y = 12H	16.2	16.6	16.7	17.1	17.6	16.2	16.6	16.7	17.1	17.6
X = 12H Y = 4H	16.3	16.9	16.8	17.3	17.8	16.3	16.9	16.8	17.3	17.8
Y = 6H	16.2	16.7	16.7	17.2	17.7	16.2	16.7	16.7	17.2	17.7
Y = 8H	16.2	16.6	16.7	17.1	17.6	16.2	16.6	16.7	17.1	17.6
	UGR Variations with Observer Position for Luminaire Spacings S									
S = 1.0H	+3.7	-16.0				+3.7	-16.0			
S = 1.5H	+6.4	-36.1				+6.4	-36.1			
S = 2.0H	+8.4	-48.5				+8.4	-48.5			

Colour properties

Correlated Colour Temperature : 4000

Ra: CRI (Ra) 80

ETAP tomorrow's light

This document has been compiled by ETAP with the greatest possible care. However, the information contained in this publication is not binding and may change due to technical development. ETAP is not liable for any damage whatsoever resulting from the use of this document.
www.etaplighting.com // Made in Belgium

Efficiency

Utilisation Factors according to IES (%)

	Room Reflection Factors (%)									
Ceiling	80	80	80	50	50	50	30	30	30	0
Walls	50	30	10	50	30	10	50	30	10	0
Floor	20	20	20	20	20	20	20	20	20	0
RCR = 1	110	109	107	104	103	102	100	99	98	93
2	102	99	96	97	94	92	94	92	90	85
3	94	90	87	90	87	84	87	85	82	78
4	87	82	78	84	80	77	81	78	75	72
5	81	75	71	78	73	70	76	72	69	66
6	75	69	65	73	68	64	71	67	64	61
7	70	64	60	68	63	59	67	62	59	56
8	65	59	55	64	58	55	62	58	54	52
9	61	55	51	60	54	51	59	54	50	49
10	57	51	47	56	51	47	55	50	47	45


Utilisation Factors according to LiTG (%)


	Room Reflection Factors (%)									
Ceiling	80	80	80	50	50	50	50	50	30	0
Walls	50	30	50	30	50	30	50	30	30	0
Floor	30	30	10	10	30	30	10	10	10	0
k = 0.60	71	65	68	63	69	64	67	62	62	58
0.80	82	75	77	72	79	73	75	71	71	67
1.00	89	82	83	78	85	80	81	77	77	72
1.25	98	92	90	86	94	89	88	85	85	81
1.50	103	97	93	90	97	93	91	89	88	84
2.00	109	104	97	95	102	99	95	93	92	88
2.50	113	108	100	98	105	102	97	96	94	91
3.00	117	113	102	100	108	106	100	98	97	94
4.00	119	116	103	102	110	107	100	99	98	94
5.00	122	119	104	103	112	110	102	101	99	96

ETAP tomorrow's light

This document has been compiled by ETAP with the greatest possible care. However, the information contained in this publication is not binding and may change due to technical development. ETAP is not liable for any damage whatsoever resulting from the use of this document.
www.etaplighting.com // Made in Belgium

Dimensional drawing





ETAP tomorrow's light

This document has been compiled by ETAP with the greatest possible care. However, the information contained in this publication is not binding and may change due to technical development. ETAP is not liable for any damage whatsoever resulting from the use of this document.
www.etaplighting.com // Made in Belgium