

# ATTESTATION OF CONFORMITY

Issued to: Etap N.V.  
Antwerpsesteenweg 130  
2390 Malle  
Belgium

For the product: Surface mounted luminaire with LED light source

Trade name: ETAP

Type/Model: E7 Series  
model: E7220/LED2N128200ST8

Ratings: 220-240 V, 50-60 Hz, Class I, 142 W, IP40, IK08

Manufactured by: Etap N.V.  
Antwerpsesteenweg 130  
2390 Malle  
Belgium

Subject: Ball proof test

Requirements: DIN 18032-3:2018, – Luminaires with operating voltages below 1000 V – Luminaire safety to ball throwing.



Indication:

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 2241429.00. This attestation belongs to test report no. 2241429.50

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 06 December 2019

Number: 2241429.01-AOC

DEKRA Certification B.V.



H.R.M. Barends  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed