CERTIFICATE

Issued to:
Applicant:
Etap Lighting International NV
Antwerpsesteenweg 130
2390 Malle, Belgium

Licensee:

Etap Lighting International NV Antwerpsesteenweg 130 2390 Malle, Belgium

Product : Recessed luminaire with LED light source

Trade name(s) : ETAP

Type(s)/model(s) : D7xxxxx/xxxxxVxxx

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard(s) EN 60598-1:2015, EN 60598-1:2015/A1:2018, EN 60598-1:2015/AC:2015, EN 60598-1:2015/AC:2016 and EN 60598-2-2:2012
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 947634

DEKRA hereby grants the right to use the ENEC certification mark

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 10 September 2021 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-120503

DEKRA Certification B.V.

B.T.M. Holtus Managing Director H.L. Schendstok Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL











SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : Recessed luminaire with LED light source

: IP20

Trade name(s) : ETAP

Type(s)/model(s) : D7xxxxx/xxxxxVxxx

Rated voltage/nature of supply

Rated frequency

Rated input

Ambient temperature (ta)

Classification

220-240 Vac

50/60 Hz, DC

33 W max.

ta=25°C

Class II

Degree of protection against dust,

moisture and solid objects

TESTS

Test requirements

EN 60598-1:2015 EN 60598-1:2015/A1:2018 EN 60598-1:2015/AC:2015 EN 60598-1:2015/AC:2016 EN 60598-2-2:2012

Test result

The test results are laid down in DEKRA test file 225812600.

Additional information

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF Stage 3).

- The luminaire contains a LED module which is in compliance with EN 62031:2020 (tested as part of the appliance).

The list of components is laid down in test report 2258126.50.

Conclusion

The examination proved that all requirements were met.

Factory location

Etap Lighting International NV Antwerpsesteenweg 130 2390 Malle, Belgium



Type reference code:

