

CERTIFICATE

Issued to:
Applicant:
Etap Lighting International NV
Antwerpsesteenweg 130
2390 Malle, Belgium

Licensee:
Etap Lighting International NV
Antwerpsesteenweg 130
2390 Malle, Belgium

Product : Fixed luminaire with LED light source
Trade name(s) : ETAP
Type(s)/model(s) : E6 LED series

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN IEC 60598-1:2021, EN IEC 60598-1:2021/A11:2022 and EN IEC 60598-2-1:2021
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 947634


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 19 April 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-137734

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Miranda Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Fixed luminaire with LED light source
Trade name(s)	: ETAP
Type(s)/model(s)	: E6 LED series (E62/LEDxNyy(E)D and E6A-S1ss-2K-xxx-yyy-D)
Rated voltage/nature of supply	: 220-240 Vac
Rated frequency	: 50-60 Hz
Rated power	: 58 Wmax.
Ambient temperature	: ta: 25 °C
Class	: I
Degree of protection	: IP66

TESTS**Test requirements**

EN IEC 60598-1:2021
EN IEC 60598-1:2021/A11:2022
EN IEC 60598-2-1:2021

Test result

The test results are laid down in DEKRA test file 228049700.

Additional information

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF Stage 3).

The luminaire contains a LED module which is in compliance with EN IEC 62031:2020+A11:2021 (tested as part of the appliance).

This certificate replaces certificate No. 71-100365 which we hereby declare invalid.

The list of components is laid down in test report 2280497.51.

Conclusion

The examination proved that all requirements were met.

Factory location

Etap Lighting International NV
Antwerpsesteenweg 130
2390 Malle, Belgium

E6 LED Family

E62/LED4N60(E)D (example)

E62/LEDxNyy(E)D

E6	2	/	LED	x	N	yy	(E)	D
DRIVER S Static D DALI dim								
EMERGENCY E 1 hour autonomy F 3 hours autonomy								
LUMINOUS FLUX 30 3000 lm (30 Wmax) 40 4000 lm (40 Wmax) 60 6000 lm (58 Wmax)								
LAMPCOLOUR N natural white								
LENGTH 2 880 mm 3 1260 mm 4 1640 mm								
LAMPTYPE LED LED								
LIGHT DISTRIBUTION 2 Wide Beam (WB)								
PRODUCT GROUP E6								

Example models:

E62/LED2N30(*)* = max 30W

E62/LED3N40(*)* = max 40W

E62/LED4N60(*)* = max 58W

E6A-S1ss-2K-xxx-yyy-D

E6A-S104-2K960-060D : 51 W max