

# CERTIFICATE

Issued to:  
Applicant:  
**Etap Lighting International NV**  
Antwerpsesteenweg 130  
2390 Malle, Belgium

Licensee:  
**Etap Lighting International NV**  
Antwerpsesteenweg 130  
2390 Malle, Belgium

Product : Recessed luminaire with LED light source  
Trade name(s) : ETAP  
Type(s)/model(s) : U3B... series (U3B-Mxxx-xx-xxx-xxxx)

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN IEC 60598-1:2021, EN IEC 60598-1:2021/A11:2022 and EN IEC 60598-2-2:2024
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 947634


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 10 October 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-101285 REV.1

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



MT Tonsi  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Recessed luminaire with LED light source
Trade name(s)	: ETAP
Type(s)/model(s)	: U3B... series (U3B-Mxxx-xx-xxx-xxxx)
Rated voltage / Nature of supply	: 220-240 Vac
Rated frequency	: 50-60 Hz
Rated input power	: 63 W max.
Ambient temperature	: ta: 25 °C
Classification	: Class I
Degree of protection against ingress of dust, solid objects and moisture	: IP20

**TESTS****Test requirements**

EN IEC 60598-1:2021  
EN IEC 60598-1:2021/A11:2022  
EN IEC 60598-2-2:2024

**Test result**

The test results are documented in DEKRA test file 229198700.

**Additional information**

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the ENEC certification system under supervision of DEKRA (CTF Stage 3).

The luminaires contain a LED module which is in compliance with EN IEC 62031:2020+A11:2021 (tested as part of the appliance).

A representative model was evaluated according IEC/TR 62778 blue light hazard and complies with non-GLS Risk Group 1 (labelling is not required)

This certificate replaces certificate No. 71-101285 which we hereby declare invalid.

The list of components is laid down in test report 2291987.50.

**Conclusion**

The examination has confirmed that all requirements were met.

**Factory location**

Etap Lighting International NV  
Antwerpsesteenweg 130  
2390 Malle, Belgium

**PRODUCT KEY**

<b>Range</b>	<b>U</b>	<b>Range name</b>	U3 range with shielded lens technology minimizing glare.
	<b>3</b>	<b>Generation</b>	B = Gen 2
-			
<b>Mechanical definition</b>	<b>M</b>	<b>Installation</b>	M = modulated ceiling
	<b>x</b>	<b>Modulation</b>	1 = M300 (1200x300) 2 = M600 (600x600) 8 = M625 (625x625)
	<b>0</b>	<b>Number of optical units</b>	01 = 1 unit 02 = 2 units 03 = 3 units 04 = 4 units 05 = 5 units 06 = 6 units 07 = 7 units
<b>x</b>			
-			
<b>Optics</b>	<b>x</b>	<b>Light distribution</b>	1 = Medium 2 = Wide 3 = Very wide
	<b>5</b>	<b>Finish / Material</b>	5 = White optical unit 1 = Alu optical unit
-			
<b>Light source</b>	<b>8</b>	<b>CRI</b>	8 = CRI80
	<b>x</b>	<b>Light temp.</b>	30 = 3000K 40 = 4000K
	<b>x</b>		
-			
<b>Flux &amp; Driver</b>	<b>x</b>	<b>Flux</b>	2000 to 8200 lm
	<b>x</b>		
	<b>x</b>		
	<b>x</b>	<b>Driver</b>	S = static D = Dali

**MAXIMUM WATTAGES**

Square		Linear	
U3B-M201** = 1 unit	18 W	/	
U3B-M202** = 2 units	33 W	/	
U3B-M203** = 3 units	48 W	/	
U3B-M204** = 4 units	63 W	U3B-M104** = 4 units	63 W
U3B-M205** = 5 units	36 W	/	
U3B-M206** = 6 units	43 W	U3B-M106** = 6 units	43 W