

# CERTIFICATE

Issued to:  
Applicant:  
**Etap Lighting International NV**  
**Antwerpsesteenweg 130**  
**2390 Malle, Belgium**

Licensee:  
**Etap Lighting International NV**  
**Antwerpsesteenweg 130**  
**2390 Malle, Belgium**

Product : Recessed luminaire with LED light source  
Trade name(s) : ETAP  
Type(s)/model(s) : U7C series

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN IEC 60598-1:2021, EN IEC 60598-1:2021/A11:2022 and EN IEC 60598-2-2:2024
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 947634


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 11 February 2025 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-127198 REV.1

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



Susan Lehner  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Recessed luminaire with LED light source
Trade name(s)	: ETAP
Type(s)/model(s)	: U7C series (U7C-MXXX-XX-XXX-XXXX)
Rated voltage/nature of supply	: 220-240 Vac/dc
Rated frequency	: 50-60 Hz / DC
Max. rated input	: 58 Wmax.
Ambient temperature	: ta: 25 °C
Class	: class I
Degree of protection	: IP20

**TESTS****Test requirements**

EN IEC 60598-1:2021  
EN IEC 60598-1:2021/A11:2022  
EN IEC 60598-2-2:2024

**Test result**

The test results are documented in DEKRA test file 229623600.

**Additional information**

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturer's right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (CTF Stage 3).

The luminaire contains a LED module which is in compliance with EN IEC 62031:2020+A11:2021 (tested as part of the appliance).

This certificate replaces certificate No. 71-127198 which we hereby declare invalid.

The list of components is laid down in test report 2296236.50.

**Conclusion**

The examination has confirmed that all requirements were met.

**Factory location**

Etap Lighting International NV  
Antwerpsesteenweg 130  
2390 Malle, Belgium

U7C	-	MX	XX	-	X	X	-	XXX	-	XXX	X	(+XXXXXXXX)
												<b>Configured options</b>
												<b>Driver</b> D – Dali S - Static
												<b>Light Output (x100)</b> 020 ± 2000 lm – Max 17 W 082 ± 8200 lm – Max 58 W ... ..
												<b>CRI value – Light Color</b> 830 CRI (Ra) 80, 3000K 840 CRI (Ra) 80, 4000K 950 CRI (Ra) 90, 5000K ... ..
												<b>Optics</b> <b>Material – Finish</b> 5 White Cups ..... <b>Light Distribution</b> 1 Medium 2 Wide 3 Very Wide 5 Asymmetric
												<b>Mechanical Definition</b> <b>XX Number of cups: 12-18-24-36-48 ...</b> <b>M1</b> Modulation ceiling 300 mm <b>M2</b> Modulation ceiling 600 mm <b>M8</b> Modulation ceiling 625 mm
<b>U7C Recessed luminaire with flat diffusor – Generation ‘C’</b>												