

CERTIFICATE

Issued to:
Applicant:
Etap N.V.
Antwerpsesteenweg 130
2390 Malle,
Belgium

Manufacturer/Licensee:
Etap N.V.
Antwerpsesteenweg 130
2390 Malle,
Belgium

Product : Luminaire with LED light source
Trade name : ETAP
Model : US SERIES

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60598-1:2015; EN 60598-2-2:2012; EN 62031:2008
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 947634

DEKRA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: 6 July 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2183816.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



A.P. van der Veen
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	: Luminaire with LED light source
trade name	: ETAP
model	: US series
product key	: US****/LED***(.)***, for more details, refers to the attachment on page 4.
rated voltage	: 220-240 V
nature of supply	: ac
rated frequency	: 50-60 Hz
input power	: 39 W max, for more details, refers to the attachment on page 5.
ambient temperature (ta)	: 25 °C
class	: I
degree of protection	: IP20
description	: recessed luminaire with LED light source

Additional information

For more details refers to test report 2183816.50

TESTS**Test requirements**Main test requirements:

EN 60598-1:2015

EN 60598-2-2:2012

Additional test requirements:

EN 62031:2008 + A1:2013 + A2:2015

Test results

The test results are laid down in DEKRA test file 2183816.00.

Conclusion

The examination proved that all test requirements were met.

The tests were performed by the manufacturer under the conditions of the agreement concerning the manufacturers right to conduct type tests for the KEMA-KEUR / ENEC certification system under supervision of DEKRA (Supervised Manufacturers Testing).

Supervised by : H.J.H. te Lindert



Checked by : L.N.H. Huynh

**Factory location**

Etap N.V.
Antwerpsesteenweg 130, 2390 Malle
Belgium