

DECLARATION OF CONFORMITY

We,

ETAP Verlichting N.V.

Antwerpsesteenweg 130, 2390 Malle, België

Declare under our sole responsibility that the listed products:

KE2*/6*

are suitable for use in food-processing companies, which use a food safety system based on HACCP according IFS version 6, or BRC Global Standard Food version 7.

These luminaires are IP69K, and therefore tested for cleaning with water at 80°C under high pressure.

These luminaires do not contain glass, the lens is made of polycarbonate and withstands an impact energy of 2 Joule (IK07).

These luminaires have a luminous flux of 550 lumen in emergency mode, with a light color of 5000K and a color rendering of $R_a > 80$, with which an adequate lighting can be made to allow for a safe evacuation.

The professional installation and maintenance of the luminaires, as well as regular hygiene checks, and proper cleaning and disinfection measures, remain the responsibility of the food-processing plant owners and operators, and are mandatory to obtain the required level of hygiene.



Greet Verhoeven
Head product development
Malle, 25/06/2019